

Certificate of Product Approval

Certificate Number: 010ag

Issue: 13

Apollo Fire Detectors Limited

36 Brookside Road
Havant, Hampshire
P09 1JR
United Kingdom



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Line Units

XP95 Range of Line Units, S65 Conventional Relay Bases and Orbis Bases

Standards

EN 54-18:2005

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

M McCullagh
Verifier

17 February 2015
Date of Issue

10 March 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 010ag Apollo Fire Detectors Limited

Issue: 13

Certified Product	Description	LPCB Ref.No.
45681-242	XP95 Analogue Addressable Low Power Relay Base	010ag/01
45681-245	S65 Conventional Standard Relay Base	010ag/02
45681-246	S65 Conventional Auxiliary Relay Base	010ag/03
45681-247	S65 Conventional end of line 12V Relay Base	010ag/04
45681-248	S65 Conventional end of line 24V Relay base	010ag/05
45681-508	S65 Conventional 12V relay base	010ag/06
55000-181	XP95 Analogue Addressable DIN-rail 8A Sounder Controller Unit	010ag/07
55000-182	XP95 Analogue Addressable DIN-rail Sounder Control Unit	010ag/08
55000-797	XP95 Analogue Addressable DIN-rail Mains Input/Output Unit Note: 1. To ensure compliance is maintained, this device shall be installed within an enclosure weighing greater than 4.75kg.	010ag/09
55000-803	XP95 Analogue Addressable DIN-rail Input/Output Unit Note: 1. To ensure compliance is maintained, this device shall be installed within an enclosure weighing greater than 4.75kg.	010ag/10
55000-804	XP95 Analogue Addressable DIN-rail Output Unit Note: 1. To ensure compliance is maintained, this device shall be installed within an enclosure weighing greater than 4.75kg.	010ag/11
55000-821	XP95 Analogue Addressable DIN-rail Switch Monitor Plus	010ag/12
55000-822	XP95 Analogue Addressable DIN-rail Switch Monitor	010ag/13
55000-855	XP95 Analogue Addressable DIN-rail Protocol Translator - Single Note: 1. To ensure compliance is maintained, all connecting cables to the protocol translator shall be less than 3m.	010ag/14
55000-856	XP95 Analogue Addressable DIN-rail Protocol Translator - Dual Note: 1. To ensure compliance is maintained, all connecting cables to the protocol translator shall be less than 3m.	010ag/15
55000-875	XP95 Analogue Addressable Mains Switch Input/Output Unit	010ag/16

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

M McCullagh
Verifier

17 February 2015
Date of Issue

10 March 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 010ag Apollo Fire Detectors Limited

Issue: 13

Certified Product	Description	LPCB Ref.No.
ORB-RB-10004	Orbis TimeSaver relay base	010ag/17
ORB-SW-10005	Orbis Sav-wire base	010ag/18

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

M McCullagh
Verifier

17 February 2015
Date of Issue

10 March 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com




Appendix to Certificate No: 010ag Apollo Fire Detectors Limited

Issue: 13

Alternative Model Numbers and Labelling

LPCB Ref No.	Model No.	Alternative Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
010ag/02	45681-245	45681-245AMP	AMPAC Technologies PTY Ltd	010ag-(cl-2)
010ag/02	45681-245	SHB90002	Safety Hi-Tech Srl	010ag-(cl-3)
010ag/08	55000-182	EMI-401/S	Pelco Finland Oy	010ag-(cl-1)
010ag/10	55000-803	EMI-411	Pelco Finland Oy	010ag-(cl-1)
010ag/11	55000-804	EMI-401	Pelco Finland Oy	010ag-(cl-1)
010ag/12	55000-821	EMI-410+	Pelco Finland Oy	010ag-(cl-1)
010ag/13	55000-822	EMI-410	Pelco Finland Oy	010ag-(cl-1)
010ag/16	55000-875	EMI-311/240	Pelco Finland Oy	010ag-(cl-1)
010ag/16	55000-875	S-A4052	Shield Fire, Safety and Security Ltd	010ag-(cl-4)
010ag/02	45681-245	200-303	Eurotech Fire Systems Ltd	1213g
010ag/16	55000-875	200-208	Eurotech Fire Systems Ltd	1213g
010ag/16	55000-875	55000-875HSL	Haes Systems Limited	810f

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

M McCullagh
Verifier

17 February 2015
Date of Issue

10 March 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre