

Certificate of Product Approval

Certificate Number: 1174e

Issue: 03

Beijing VSAIL Fire Protection Equipment Co Ltd

No 401, Unit A, Building 32,
Huilongsen Hi-Tech Park,
No 99 14th Kechuang Street,
BDA,
Beijing 100176



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Control and Indicating Equipment

VC-6831/16

VC-6831/8

VC-6831/4

VC-6831/2

(refer to Appendix for details)

Standards

EN 54-2:1997 + A1:2006

EN 54-4:1997 + A1:2002 + A2:2006

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

Eman Mattie-Suleiman

Verifier

16 November 2016

Date of Issue

05 May 2015

Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 1174e Beijing VSAIL Fire Protection Equipment Co Ltd

Issue: 03

| Certified Product | Description | LPCB Ref.No. |
|-------------------|---|--------------|
| VC-6831/16 | <p>16 Zone Conventional Control and Indicating Equipment</p> <p>Incorporating the following units:</p> <p>VSL2.908.004 16 Zone Control Board VSL2.908.007 16 Zone Display Board PD-100-24 AC/DC Power Supply Module VSL2.908.005 16 Zone Signal Output Board</p> <p>Certified with the following Options with requirements from EN 54-2:1997</p> <p>7.8 Output to fire alarm device(s) 7.11 Delay to outputs 10 Test condition</p> <p>Note: 1. This approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.</p> | 1174e/01 |
| VC-6831/8 | <p>8 Zone Conventional Control and Indicating Equipment</p> <p>Incorporating the following units:</p> <p>VSL2.908.042 8 Zone Control Board VSL2.908.043 8 Zone Display Board PD-100-24 AC/DC Power Supply Module</p> <p>Certified with the following Options with requirements from EN 54-2:1997</p> <p>7.8 Output to fire alarm device(s) 7.11 Delay to outputs 10 Test condition</p> | 1174e/02 |

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for LPCB

Eman Mattie-Suleiman
Verifier

16 November 2016
Date of Issue

05 May 2015
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 1174e Beijing VSAIL Fire Protection Equipment Co Ltd

Issue: 03

| Certified Product | Description | LPCB Ref.No. |
|-------------------|---|--------------|
| | Note: 1. This approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13. | |
| VC-6831/4 | 4 Zone Conventional Control and Indicating Equipment Incorporating the following units: VSL2.908.044 4 Zone Control Board VSL2.908.045 4 Zone Display Board PD-100-24 AC/DC Power Supply Module Certified with the following Options with requirements from EN 54-2:1997 7.8 Output to fire alarm device(s) 7.11 Delay to outputs 10 Test condition Note: 1. This approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13. | 1174e/03 |
| VC-6831/2 | 2 Zone Conventional Control and Indicating Equipment Incorporating the following units: VSL2.908.046 2 Zone Control Board VSL2.908.047 2 Zone Display Board PD-100-24 AC/DC Power Supply Module Certified with the following Options with requirements from EN 54-2:1997 7.8 Output to fire alarm device(s) | 1174e/04 |

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for LPCB

Eman Mattie-Suleiman
Verifier

16 November 2016
Date of Issue

05 May 2015
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 1174e Beijing VSAIL Fire Protection Equipment Co Ltd

Issue: 03

| Certified Product | Description | LPCB Ref.No. |
|--|--|--------------|
| | 7.11 Delay to outputs 10 Test condition | |
| Note: 1. This approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13. | | |

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

Eman Mattie-Suleiman
Verifier

16 November 2016
Date of Issue

05 May 2015
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com




Appendix to Certificate No: 1174e Beijing VSAIL Fire Protection Equipment Co Ltd

Issue: 03

Alternative Model Numbers and Labelling

| LPCB Ref No. | Model No. | Alternative Model No./Label | Cross-listed company | Cross-Listed Co Cert./ Ref No. |
|--------------|------------|-----------------------------|------------------------------------|--------------------------------|
| 1174e/01 | VC-6831/16 | VG-6831/16 | V-GREAT Global Corporation | 1174e-(cl-1) |
| 1174e/01 | VC-6831/16 | B61-801/16 | Bristol Fire Engineering LLC | 1174e-(cl-2) |
| 1174e/01 | VC-6831/16 | FS-100/16 | Fire Safety Co. | 1174e-(cl-3) |
| 1174e/01 | VC-6831/16 | SC-6831/16 | Al Rayan Security & Safety Trading | 1174e-(cl-6) |
| 1174e/02 | VC-6831/8 | VG-6831/8 | V-GREAT Global Corporation | 1174e-(cl-1) |
| 1174e/02 | VC-6831/8 | B61-801/8 | Bristol Fire Engineering LLC | 1174e-(cl-2) |
| 1174e/02 | VC-6831/8 | FS-100/8 | Fire Safety Co. | 1174e-(cl-3) |
| 1174e/02 | VC-6831/8 | SC-6831/8 | Al Rayan Security & Safety Trading | 1174e-(cl-6) |
| 1174e/03 | VC-6831/4 | VG-6831/4 | V-GREAT Global Corporation | 1174e-(cl-1) |
| 1174e/03 | VC-6831/4 | B61-801/4 | Bristol Fire Engineering LLC | 1174e-(cl-2) |
| 1174e/03 | VC-6831/4 | FS-100/4 | Fire Safety Co. | 1174e-(cl-3) |
| 1174e/03 | VC-6831/4 | SC-6831/4 | Al Rayan Security & Safety Trading | 1174e-(cl-6) |
| 1174e/04 | VC-6831/2 | VG-6831/2 | V-GREAT Global Corporation | 1174e-(cl-1) |
| 1174e/04 | VC-6831/2 | B61-801/2 | Bristol Fire Engineering LLC | 1174e-(cl-2) |
| 1174e/04 | VC-6831/2 | FS-100/2 | Fire Safety Co. | 1174e-(cl-3) |
| 1174e/04 | VC-6831/2 | SC-6831/2 | Al Rayan Security & Safety Trading | 1174e-(cl-6) |

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

Eman Mattie-Suleiman
Verifier

16 November 2016
Date of Issue

05 May 2015
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre