

www.redbooklive.com

# Certificate of Product Approval

Certificate Number: 1174c

Issue: 03

## **Beijing VSAIL Fire Protection Equipment Co Ltd**

No. 401, Unit A, Building 32, No. 99 14th Kechuang Street BDA Beijing 100176 China

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

### **Products**

Audible Warning Devices VC-6734 VI-6737 (refer to Appendix for details)

### Standards

EN 54-3:2001 + A1:2002 + A2:2006

R

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

F. Halliger Signed for LPCB	P Halligan04 May 201625 June 2014VerifierDate of IssueDate of First Issue			
NUN CERTIFICE	This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).			
	To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.			
CERTIFICATION 0007	LPCB is part of BRE Global Ltd, Watford T: +44 (0)333 321 8811 F: +44 (0)1923			Dre



# Appendix to Certificate No: 1174c Beijing VSAIL Fire Protection Equipment Co Ltd

Issue: 03

Certified Product	Description	LPCB Ref.No.
VC-6734	<ul> <li>Conventional Type A Sounder Strobe (VB-6711 Base) Notes:</li> <li>Meets the requirements of EN 54-3 and approved at the following tones:</li> <li>Tone 01, 2400Hz – 2900Hz @ 3 Hz</li> <li>Tone 10, 500Hz – 1200Hz x 3, 3.5s on / 0.5s off</li> <li>The strobe function is not included within the scope of this approval</li> </ul>	1174c/01
VI-6737	<ul> <li>Addressable Type A Indoor Digital Sounder Beacon (VB-6619 Base) Notes:</li> <li>1. Meets the requirements of EN 54-3 and approved at the following tones:</li> <li>1) Tone 00, 2400Hz – 2900Hz @ 3Hz</li> <li>2) Tone 01, 2400Hz – 2900Hz @ 9Hz</li> <li>3) Tone 08, 500Hz – 1200Hz x 3, 3.5s on / 0.5s off</li> <li>4) Tone 14, 1500Hz – 2700Hz @ 3Hz</li> <li>2. The beacon function is not included within the scope of this approval</li> </ul>	1174c/02

#### Base:

VB-6711Addressable Mounting BaseVB-6619Addressable Mounting Base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P. Hallign	P Halligan	04 May 2016	25 June 2014	
Signed for LPCB	Verifier Date of Issue Date of First Issue This certificate and appendix remain the property of BRE Global Ltd and are			
	issued subject to terms and conditions (for details visit www.redbooklive.com/terms). To check the validity of this certificate and appendix please visit			
CERTIFICATION 0007	www.redbooklive.com/check, scan the LPCB is part of BRE Global Ltd, Watford T: +44 (0)333 321 8811 F: +44 (0)192	d, WD25 9XX	s bre	

80018